


CONFIRM ACTUAL TRANSFORMER DIMENSIONS. IF THEY EXCEED THOSE LISTED. SIZE THE EQUIPMENT SUPPORT PAD ACCORDINGLY.




TRANSFORMER SIDE ELEVATION

-STEEL BARRIER HIGH VOLTAGE-STANDOFF BRACKET NAME PLATE/ID TAG PERMANENTLY ATTACHED BAYONET FUSE IN--PRESSURE RELIEF VALVE SERIES WITH CURRENT LIMITING FUSE --OIL FILL Ł -LOW VOLTAGE BUSHING -LOW VOLTAGE GROUND STRAP HIGH VOLTAGE--OIL DRAIN WITH SAMPLING DEVICE BUSHINGS -GROUND PAD В

TRANSFORMER FRONT DOOR OPEN ELEVATION

NOTES:

- 1. POWER COMPANY SERVICE POINT, SINGLE PHASE VOLTAGE WITH DISCONNECTING PROVISIONS, POWER COMPANY TO RUN UNDER GROUND CABLE CONNECTION IN CONTRACTOR FURNISHED TRENCH TO TRANSFORMER HIGH VOLTAGE TERMINALS.
 - A. CONTRACTOR CONTACTS SERVING POWER COMPANY TO VERIFY PRIMARY VOLTAGE AND TYPE OF CONNECTION.
 - B. CONTRACTOR NOTIFIES SERVING POWER COMPANY A MINIMUM OF 24 HOURS IN ADVANCE OF DESIRED POWER SOURCE CONNECTION.
- 2. LOCATE SERVICE PEDESTAL ON EITHER SIDE OF CONTROLLER FOUNDATION AS SPECIFIED. LOCATION MAY BE MODIFIED TO BEST SUIT FIELD CONDITIONS PER RESIDENT ENGINEER APPROVAL. MAINTAIN 48 INCH MINIMUM CLEARANCE AROUND EACH UNIT WITH DOORS OPENED TO ANY POSITION.
- 3. LOCATE SERVICE PEDESTAL AND TRANSFORMER SO WATER DRAINS AWAY FROM FOUNDATIONS AND JUNCTION BOXES. SITE PREPARATION INCLUDING GRADING MAY BE REQUIRED BEFORE PLACING EQUIPMENT.
- 4. PROVIDE UNDERGROUND SERVICE PEDESTAL:
 - A. RATED 100 AMP AS SPECIFIED.
 - B. PROVIDE FOR SIX FULL SIZE POLES (INCLUDING MAINS) FOR BOTH METERED AND UN-METERED CIRCUIT BREAKER INTERIORS.
 - C. USE PLUG-IN CIRCUIT BREAKERS.
 - D. LABEL ALL BREAKERS.
 - E. FUSE DETACHABLE BASE FOR PRE-INSTALLATION IN CONCRETE FOUNDATION.
 - F. SECURE PIANO HINGED DOORS WITH



CAST-IN-PLACE OR PRECAST.

2. PREFABRICATED POLYMER

CONCRETE.

SUPPLEMENTAL DRAWING

LE TRANSFORMER SUBSTATION **DETAIL** INGL S SL 18

RANSPORTATION
BRIDGE CONSTRUCTION

UTAH